



NOTES:

1. METERS, METER VALVES & CHECK VALVES PROVIDED BY TOWN.
2. A 6' DIA MANHOLE MAY BE SUBSTITUTED FOR 4 OR LESS METERS.
3. IF NO PROFILE, PIT HEIGHT TO CEILING ≥ 6'-0" FLOOR TO BE 1" WASHED STONE.
4. MINIMUM METER HEIGHT 12" FROM BASE.
5. HATCH TO BE BILCO TYPE PDCM (30" MIN. OPENING) OR APPROVED EQUAL.



TOWN OF MILTON
PUBLIC WORKS DEPARTMENT

SCALE: NTS

DATE: FEB. 2008

DRAWING # 23

DRAWN BY: F&A

TYPICAL 2" MULTIPLE UNIT METER PIT