



SADDLE SHALL BE PROVIDED FOR ALL CONNECTIONS TO PVC PIPE. TAPS INTO DI PIPES SHALL BE DIRECTLY TAPPED. TAPS INTO HDPE PIPES SHALL BE THERMALLY FUSED

WATER MAIN CORPORATION STOP, DIRECT TAP ON ALL DI PIPE

COMPRESSION TYPE FITTINGS

GOOSENECK NOT TO EXTEND ABOVE APEX OF MAIN

1'X1'X4' CONCRETE BLOCK

TYPE "K" COPPER SERVICE PIPE SIZED AS REQUIRED.

FINISHED GRADE

6' MIN.

BRASS PENTAGON PLUG COVER

STAINLESS STEEL OPERATING ROD

CURB STOP AND BOX

COMPRESSION TYPE FITTINGS



TOWN OF MILTON
PUBLIC WORKS DEPARTMENT

NOTES:

1. TAP FOR SERVICE SHALL BE AT 3 OR 9 O'CLOCK.

SCALE: NTS

DATE: FEB. 2008

DRAWING # 20

DRAWN BY: FA&A

TYPICAL CORPORATION STOP AND CURB BOX