



**NOTES:**

1. POST HYDRANTS SHALL BE NON-DRAINING TYPE WITH A 6' BURY DEPTH. THESE HYDRANTS SHALL BE FURNISHED WITH A HORIZONTAL INLET, A NON-TURNING OPERATING ROD, AND SHALL OPEN TO THE LEFT. ALL OF THE WORKING PARTS SHALL BE OF BRONZE-TO-BRONZE DESIGN, AND BE SERVICEABLE FROM ABOVE GRADE WITH NO DIGGING. THE OUTLET SHALL ALSO BE BRONZE AND BE 2-1/2" NST. HYDRANTS SHALL BE LOCKABLE TO PREVENT UNAUTHORIZED USE AS MANUFACTURED BY KUPFERLE FOUNDRY Co., St. LOUIS, MO, OR APPROVED EQUAL. SUGGESTED DETAIL FOR DEADENDS, 8" IN DIA. OR LESS. 2" FOR MAINS  $\leq$  6". 4" FOR MAINS  $\geq$  8".

	<b>TOWN OF MILTON</b> <b>PUBLIC WORKS DEPARTMENT</b>	
	SCALE: NTS	DATE: FEB. 2008
DRAWING #: 27	DRAWN BY: FA&A	
<b>TYPICAL BLOW-OFF HYDRANT WITH HORIZONTAL INLET</b>		