



TYPICAL ON BOTH SIDES THE CUT OR FILL NOT TO BE STEEPER THAN 3 ON 1 EXTENDED ON TO LOT TO MEET ORIGINAL GROUND

1-1/2" TYPE IV WEARING COURSE PAVEMENT

2-1/2" TYPE II BASE COURSE PAVEMENT

6" THICK CRUSHED GRAVEL AS PER VT STATE SPEC #704.05 (fine)

24" THICK GRAVEL BASE AS PER VT STATE SPEC #704.06

SUBBASE SOILS (LEDGE SHALL BE FRACTURED A MINIMUM OF 12" BELOW SUBGRADE) 12" + O.D.

SPECIAL ROADWAY SECTION WITH UNDERDRAIN OR IF REQUIRED BY TESTS IN NOTE #2

STANDARD ROADWAY SECTION WITHOUT UNDERDRAIN

**NOTES:**

1. SOIL BORINGS AND TEST PITS MAY BE REQUIRED BY THE TOWN TO DETERMINE WHETHER THE STANDARD OR SPECIAL CROSS-SECTION SHALL BE USED.
2. THE SPECIAL SECTION WITH THE 24" GRAVEL BASE AND UNDERDRAIN SHALL BE USED WHEN THE PLASTICITY INDEX OF THE SUBGRADE IS MORE THAN 6 AND THE LIQUID LIMIT IS GREATER THAN 25. WHEN THE SUBGRADE SOILS CONTAIN MORE THAN 8% BY WEIGHT OF PARTICLES FINER THAN A #200 SIEVE OR WHEN THE SEASONAL HIGH GROUNDWATER IS WITHIN 3' OF THE FINISH GRADE.



TOWN OF MILTON  
PUBLIC WORKS DEPARTMENT

SCALE: NTS

DATE: FEB. 2008

DRAWING #: 1

DRAWN BY: FA&A

TYPICAL ROAD CROSS-SECTION WITHOUT CURBS AND SIDEWALKS