



NOTES:

1. IF DEPTH OF MANHOLE IS 7 FEET OR LESS FROM RIM TO INVERT THEN A FLAT TOP SHALL BE INSTALLED. IF DEPTH OF MANHOLE FROM RIM TO INVERT IS MORE THAN 7 FEET THEN A CONICAL TOP SHALL BE INSTALLED.

	TOWN OF MILTON PUBLIC WORKS DEPARTMENT	
	SCALE: NTS	DATE: FEB. 2008
DRAWING #: 30	DRAWN BY: FA&A	
TYPICAL SANITARY SEWER MANHOLE		