



- NOTES:**
1. TAPPING SLEEVE AND VALVES ON CWD TRANSMISSION MAINS ARE TO MEET CHAMPLAIN WATER DISTRICT "STANDARD SPECIFICATION FOR TAPPING SLEEVES AND TAPPING VALVES" ALL OTHER TAPPING SLEEVES AND TAPPING VALVES ARE TO MEET APPROPRIATE DISTRIBUTION SYSTEM SPECIFICATIONS.
 2. WET TAPS SHALL BE PERFORMED BY PRE-APPROVED FIRMS ONLY.
 3. ALL FITTINGS THAT ARE TO HAVE CONCRETE POURED AROUND THEM ARE TO BE WRAPPED WITH 4 MIL. POLYETHYLENE PRIOR TO CONCRETE PLACEMENT.



TOWN OF MILTON	
PUBLIC WORKS DEPARTMENT	
SCALE: NTS	DATE: FEB. 2008
DRAWING # : 25	DRAWN BY: FA&A

TYPICAL TAPPING SLEEVE AND VALVE DETAIL